



Discover The Possibilities™



Disable Lutron Login

Compass Navigator

Disable Lutron Login in Module

- Add Lutron to Modular/Custom Project.
- Save and then open Lutron Module, which will be found in the Project “_res” Folder.
- Go to the Variables Tab and expand the Project Variables.
- Locate “Lutron_Restart_Request” Variable
 - Under Events and Actions for the restart request variable, add the following:
 1. Variable change for “Lutron_Login”, set it to “lutron”.
 2. Variable change for “Lutron_Password”, set it to “integration”.
 3. Macro Command, send a “restartControl” command.
 4. Quit Action, to prevent login screen from popping up.
- No further changes are needed. Save module and return to Project.
- Below is how the “Lutron_Restart_Request” variable should look for its Events and Actions.

