

Navigator Variable to Hex 1-Way Library

Navigator Variable s/b Integer

Library format should be Hex. Set in Device Properties

Library function Parameter(s) should be %d (%02d not necessary) (not %x)